

SENSAPHONE®

REMOTE MONITORING SOLUTIONS

SENSAPHONE SPOT WATER DETECTION SENSOR • FGD-0013 v2.7
Installation Instructions

The Spot Water Detection Sensor will detect the presence of water at its probes. The Spot Water Detection Sensor can be used with all models of Sensaphone®. The sensor is a normally closed (N.C.) device that is polarity sensitive.

Wiring Instructions

1. Connect the red wire (positive) from the sensor to an alert input on the Sensaphone.
2. Connect the black wire (negative) to ground or common.
3. Configure your input normality as normally closed.
 - For models 400, 800, 1400, 1800: Press Set, then Configure to set normality.
 - For Sensaphone Sentinel, Sentinel Pro, Stratus EMS, WEB600, SAT4D, and Express II: Program the input type as normally closed.

Consult your specific Sensaphone owner's manual for further instructions.

4. Test the sensor by touching the probes with a damp paper towel.

Installing Multiple Sensors

Multiple sensors may be installed by wiring them in series, red (positive) to black (negative).

The FGD-0013 is powered by internal lithium batteries. The batteries should last for approximately 3-5 years. When the batteries start to run down, the sensor will automatically cause an alarm dial out when no water is present.

Specifications:

Normality: Normally closed

Dimensions: 2.25" x 1.125" x 3.625"

Number per input: Multiple, wired in series

Battery Replacement:

1. Remove rubber feet from bottom.
2. Remove screws from under rubber feet only.
3. Open enclosure.
4. Remove old batteries and replace with two CR1225 3V batteries.

For technical support, call 877-373-2700.

SENSAPHONE®
901 Tryens Road
Aston, PA 19014
www.sensaphone.com